



SHAKOPEE FIRE DEPARTMENT

Fire & Life Safety for a Growing Community



SIGNAGE SPECIFICATIONS Policy #20-2004 (04/01/2009) (2007 MSFC)

Address

Address number shall be provided. Refer to Shakopee Fire Department Policy #01-2000 Premises Identification.

FDC Signage

Reflective sign for FDC: Minimum 18" x 12" with engineer grade reflective sheeting. Red reflective letters on a white reflective background. Contact the Shakopee Fire Department for a list of vendors this sign may be purchased from. Refer to Signage Detail sheet for mounting location.

Door Labels

Letters shall be of a contrasting color to the background.

Exterior - Labels on exterior doors shall identify the door use and property address.
The main wording shall be in 6" letters with secondary wording in 3" letters.

Fire Access

Your Address Here

Stairs

Basement thru 4th
Roof Access

Riser Room

Your Address Here
No Building Access

Interior - Labels on interior doors shall identify the door use.

Wording shall be in 3" letters. Reduced size letters shall be pre-approved by the Shakopee Fire Department.

Fire Access

Electrical Room

Riser Room

Mechanical Room

Roof Access

Policy: #20-2004
Date: 01/01/2004
Revised: 04/01/2009 (12/01/2004)
Page 1/2
policies/20 Signage Specifications.doc

NFPA 704 Sign

An NFPA 704 diamond sign shall be provided on all buildings containing reportable quantities of hazardous materials. The minimum sign size shall be 11" x 11". Smaller signs may be approved depending on material quantities and occupancy type.



Proper information shall be placed in each colored box to represent the most hazardous level chemical located within the building.

Blue (Health)	0 – 4
Red (Flammability)	0 – 4
Yellow (Instability)	0 – 4
White (Special Precautions)	

Policy: #20-2004
Date: 01/01/2004
Revised: 04/01/2009 (12/01/2004)
Page 2/2
policies/20 Signage Specifications.doc