



SHAKOPEE FIRE DEPARTMENT

Fire & Life Safety for a Growing Community



UL CERTIFICATE REQUIREMENTS

Policy #21-2006 (04/01/2009) (2007 MSFC)

General Requirements

All fire alarm systems and sprinkler monitoring systems installed after January 1, 2004 shall be provided with a UL Certificate. The following information shall be provided on the UL Certificate.

Authority Having Jurisdiction: SHAKOPEE FIRE DEPARTMENT – OFFICE OF THE FIRE MARSHAL

Responding Fire Department: SHAKOPEE FIRE DEPARTMENT

System Deviations:

ANNUAL TESTING OF SYSTEM PER AHJ

RUNNER SERVICE NOT PROVIDED FOR FIRE DEPARTMENT KEYBOX TAMPERS

Policy: #21-2006

Date: 01/01/2006

Revised: 04/01/2009 (07/01/2007)

Page 1/1

policies/21 UL Certificate Requirements.doc

Mailing Address: 129 Holmes Street South – Shakopee, MN 55379 – Phone: 952-233-9570 – Fax: 952-233-3857

Station #1: 2700 Vierling Drive East

firesafety@ci.shakopee.mn.us

TTY: 952-233-3837

Station #2: 334 2nd Avenue West

www.ci.shakopee.mn.us