SHAKOPEE FIRE DEPARTMENT

Fire & Life Safety for a Growing Community

SHAKOPEE

FIRE PROTECTION SYSTEM INSPECTION TESTING AND MAINTENANCE RECORDS

Policy #25-2009 (04/01/2009) (2007 MSFC)

General Requirements

1. In accordance with Minnesota State Fire Code (MSFC) Section 901.6 all fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Non-required fire protection systems and equipment shall be inspected, tested and maintained or removed.

2. Records of all system inspections, tests and maintenance required by the MSFC and its referenced standards shall be maintained on the premises for a minimum of three years.

3. Copies of all system inspections, tests and maintenance records shall be copied to the Shakopee Fire Department as allowed by MSFC 901.6.2. Copies shall be sent via US Postal Service mail, fax or e-mail to the following location:

   Shakopee Fire Department
   129 Holmes St. S.
   Shakopee, MN 55379
   Fax: 952-233-3857
   Email: firesafety@ci.shakopee.mn.us

Policy: #25-2009
Date: 04/01/2009
Revised:
Page 1/1
policies/25 System Records.doc